

# Example of Manual J,D and S Forms required to be submitted

## Project Information

For: Right-Sized Residence  
ACCA Manual J Street, Oak Park, IL 60301

## Design Conditions

### Location:

Chicago Midway AP, IL, US  
Elevation: 617 ft  
Latitude: 42°N

### Outdoor:

Dry bulb (°F)  
Daily range (°F)  
Wet bulb (°F)  
Wind speed (mph)

### Heating

4  
-  
-  
15.0

### Cooling

90  
16 (L)  
73  
7.5

### Indoor:

Indoor temperature (°F)  
Design TD (°F)  
Relative humidity (%)  
Moisture difference (gr/lb)

### Heating

70  
66  
30  
27.8

### Cooling

75  
15  
50  
34.1


### Infiltration:

Method  
Construction quality  
Fireplaces

Simplified  
Average  
2 (Average)


## Heating

Component	Btuh/ft²	Btuh	% of load
Walls	4.3	6033	14.2
Glazing	23.0	5735	13.5
Doors	17.1	359	0.8
Ceilings	1.7	3310	7.8
Floors	1.9	3632	8.6
Infiltration	5.8	9719	22.9
Ducts		11276	26.6
Piping		0	0
Humidification		0	0
Ventilation		2335	5.5
Adjustments		0	0
<b>Total</b>		<b>42397</b>	<b>100.0</b>



## Cooling

Component	Btuh/ft²	Btuh	% of load
Walls	0.8	1125	6.8
Glazing	20.4	5080	30.9
Doors	7.3	154	0.9
Ceilings	1.1	2098	12.8
Floors	0.4	807	4.9
Infiltration	0.5	914	5.6
Ducts		3638	22.1
Ventilation		519	3.2
Internal gains		2120	12.9
Blower		0	0
Adjustments		0	0
<b>Total</b>		<b>16454</b>	<b>100.0</b>



Latent Cooling Load = 4609 Btuh  
Overall U-value = 0.054 Btuh/ft²-°F

Data entries checked.

# Example of Manual J, D and S Forms required to be submitted

## Project Information


For: Right-Sized Residence  
ACCA Manual J Street, Oak Park, IL 60301

## Design Conditions

Location:			Indoor:	Heating	Cooling
Chicago Midway AP, IL, US			Indoor temperature (°F)	70	75
Elevation: 617 ft			Design TD (°F)	66	15
Latitude: 42°N			Relative humidity (%)	30	50
Outdoor:	Heating	Cooling	Moisture difference (gr/lb)	27.8	34.1
Dry bulb (°F)	4	90	Infiltration:		
Daily range (°F)	-	16 ( L )			
Wet bulb (°F)	-	73			
Wind speed (mph)	15.0	7.5			

## Test for Adequate Exposure Diversity

Hourly Glazing Load



Maximum hourly glazing load exceeds average by 20.3%.

House has adequate exposure diversity (AED), based on AED limit of 30%.

AED excursion: 0 Btuh

# Example of Manual J, D and S Forms required to be submitted

## Project Information

For: Right-Sized Residence  
ACCA Manual J Street, Oak Park, IL 60301

## Design Conditions

<b>Location:</b>		<b>Indoor:</b>		<b>Heating</b>	<b>Cooling</b>
Chicago Midway AP, IL, US		Indoor temperature (°F)		70	75
Elevation: 617 ft		Design TD (°F)		66	15
Latitude: 42°N		Relative humidity (%)		30	50
		Moisture difference (gr/lb)		27.8	34.1
<b>Outdoor:</b>	<b>Heating</b>	<b>Cooling</b>	<b>Infiltration:</b>		
Dry bulb (°F)	4	90	Method		Simplified
Daily range (°F)	-	16 (L )	Construction quality		Average
Wet bulb (°F)	-	73	Fireplaces		2 (Average)
Wind speed (mph)	15.0	7.5			

## Construction descriptions

### Walls

12F-0bw: Frm wall, brk 4" ext, 1/2" wood shth, r-21 cav ins, 1/2" gypsum board int fnsh, 2"x6" wood frm

Or	Area ft²	U-value Btuh/ft²·°F	Insul R ft²·°F/Btuh	Htg HTM Btuh/ft²	Loss Btuh	Clg HTM Btuh/ft²	Gain Btuh
n	472	0.065	21.0	4.27	2014	0.80	376
e	234	0.065	21.0	4.27	999	0.80	186
s	467	0.065	21.0	4.27	1996	0.80	372
w	240	0.065	21.0	4.27	1023	0.80	191
all	1413	0.065	21.0	4.27	6033	0.80	1125

### Partitions (none)

### Windows

10D-c: 2 glazing, clr low-e outr, air gas, clad wd frm mat, clr innr, 1/4" gap, 1/8" thk; NFRC rated (SHGC=0.31)

n	54	0.350	0	23.0	1251	7.73	421
n	37	0.350	0	23.0	839	11.0	403
e	45	0.350	0	23.0	1035	34.2	1541
s	74	0.350	0	23.0	1705	18.5	1369
w	39	0.350	0	23.0	904	34.2	1347
all	249	0.350	0	23.0	5735	20.4	5080

### Doors

11E0: Door, wd sc type, wd strm

s	21	0.260	0	17.1	359	7.32	154
---	----	-------	---	------	-----	------	-----

### Ceilings

16C-38aw: Attic ceiling, asphalt shingles roof mat, r-38 ceil ins, 1/2" gypsum board int fnsh

	1938	0.026	38.0	1.71	3310	1.08	2098
--	------	-------	------	------	------	------	------

### Floors

19A-30bstp: Flr floor, frm flr, 10" thkns, r-30 cav ins, tight bsmt ovr

	1938	0.034	30.0	1.87	3632	0.42	807
--	------	-------	------	------	------	------	-----



# Example of Manual J, D and S Forms required to be submitted

## Project Information

For: Right-Sized Residence  
ACCA Manual J Street, Oak Park, IL 60301

## Design Information

	Htg	Clg	Infiltration	
Outside db (°F)	4	90	Method	Simplified
Inside db (°F)	70	75	Construction quality	Average
Design TD (°F)	66	15	Fireplaces	2 (Average)
Daily range	-	L		
Inside humidity (%)	30	50		
Moisture difference (gr/lb)	28	34		

### HEATING EQUIPMENT

Make Goodman Mfg.  
Trade GOODMAN  
Model GCH950453BX\*\*  
AHRI ref 3653909

Efficiency 95 AFUE  
Heating input 46000 Btuh  
Heating output 44000 Btuh  
Temperature rise 51 °F  
Actual air flow 800 cfm  
Air flow factor 0.020 cfm/Btuh  
Static pressure 0.60 in H2O  
Space thermostat

### COOLING EQUIPMENT

Make Goodman Mfg.  
Trade GOODMAN  
Cond SSX160241B\*  
Coil CA\*F3636\*6D\*  
AHRI ref 4652177

Efficiency 13.2 EER, 16 SEER  
Sensible cooling 18720 Btuh  
Latent cooling 5280 Btuh  
Total cooling 24000 Btuh  
Actual air flow 800 cfm  
Air flow factor 0.050 cfm/Btuh  
Static pressure 0.60 in H2O  
Load sensible heat ratio 0.78

ROOM NAME	Area (ft²)	Htg load (Btuh)	Clg load (Btuh)	Htg AVF (cfm)	Clg AVF (cfm)
Master Bedroom	240	7575	2618	151	131
Master Bath	112	2734	590	55	30
Master Wic	98	0	0	0	0
Den	150	2507	644	50	32
Dining	129	2095	506	42	25
Kitchen	176	4861	3265	97	164
Living Room	394	9296	4527	186	227
CL 2	34	0	0	0	0
Bedroom 2	192	5733	2242	114	113
Hall	126	0	0	0	0
Bath 2	90	1481	312	30	16
Bedroom 3	198	3780	1232	75	62

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



Entire House	d	1939	42397	21064	800	800
Other equip loads			2135	519		
Equip. @ 1.00 RSM				16454		
Latent cooling				609		
TOTALS		1939	42397	21064	800	800

Example of Manual J,D and S  
Forms required to be submitted

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.

# Example of Manual J, D and S Forms required to be submitted

1	Room name					Entire House					Master Bedroom				
2	Exposed wall					187.0 ft					31.0 ft				
3	Room height					9.0 ft					9.0 ft				
4	Room dimensions					d					16.0 x 15.0 ft				
5	Room area					1938.9 ft²					240.0 ft²				
	Ty	Construction number	U-value (Btuh/ft²·F)	Or	HTM (Btuh/ft²)		Area (ft²) or perimeter (ft)		Load (Btuh)		Area (ft²) or perimeter (ft)		Load (Btuh)		
					Heat	Cool	Gross	N/P/S	Heat	Cool	Gross	N/P/S	Heat	Cool	
6	W	12F-0bw	0.065	n	4.27	0.80	563	472	2014	376	144	90	383	71	
11	G	10D-c	0.350	n	22.99	7.73	54	0	1251	421	54	0	1251	421	
	G	4A5-2oc	0.350	n	22.99	11.05	37	0	839	403	0	0	0	0	
	W	12F-0bw	0.065	e	4.27	0.80	279	234	999	186	0	0	0	0	
	G	4A5-2oc	0.350	e	22.99	34.24	45	0	1035	1541	0	0	0	0	
	W	12F-0bw	0.065	s	4.27	0.80	563	467	1996	372	0	0	0	0	
	G	4A5-2oc	0.350	s	22.99	18.46	74	0	1705	1369	0	0	0	0	
	D	11E0	0.260	s	17.08	7.32	21	21	359	154	0	0	0	0	
	W	12F-0bw	0.065	w	4.27	0.80	279	240	1023	191	135	115	493	92	
	G	4A5-2oc	0.350	w	22.99	34.24	39	0	904	1347	20	0	452	673	
	C	16C-38aw	0.026	-	1.71	1.08	1938	1938	3310	2098	240	240	410	260	
	F	19A-30bstp	0.034	-	1.87	0.42	1938	1938	3632	807	240	240	450	100	

# Example of Manual J,D and S Forms required to be submitted

1	Room name					Master Bath 14.0 ft 9.0 ft      heat/cool 14.0 x 8.0 ft 112.0 ft²					Master Wic 0 ft 9.0 ft      heat/cool 14.0 x 7.0 ft 98.0 ft²				
2	Exposed wall														
3	Room height														
4	Room dimensions														
5	Room area														
	Ty	Construction number	U-value (Btuh/ft²·°F)	Or	HTM (Btuh/ft²)		Area (ft²) or perimeter (ft)		Load (Btuh)		Area (ft²) or perimeter (ft)		Load (Btuh)		
					Heat	Cool	Gross	N/P/S	Heat	Cool	Gross	N/P/S	Heat	Cool	
6	W	12F-0bw	0.065	n	4.27	0.80	126	120	510	95	0	0	0	0	
11	G	10D-c	0.350	n	22.99	7.73	0	0	0	0	0	0	0	0	
	G	4A5-2oc	0.350	n	22.99	11.05	7	0	149	72	0	0	0	0	
	W	12F-0bw	0.065	e	4.27	0.80	0	0	0	0	0	0	0	0	
	G	4A5-2oc	0.350	e	22.99	34.24	0	0	0	0	0	0	0	0	
	W	12F-0bw	0.065	s	4.27	0.80	0	0	0	0	0	0	0	0	
	G	4A5-2oc	0.350	s	22.99	18.46	0	0	0	0	0	0	0	0	
	D	11E0	0.260	s	17.08	7.32	0	0	0	0	0	0	0	0	
	W	12F-0bw	0.065	w	4.27	0.80	0	0	0	0	0	0	0	0	
	G	4A5-2oc	0.350	w	22.99	34.24	0	0	0	0	0	0	0	0	
	C	16C-38aw	0.026	-	1.71	1.08	112	112	191	121	98	98	167	106	
	F	19A-30bstp	0.034	-	1.87	0.42	112	112	210	47	98	98	184	41	



# Example of Manual J,D and S Forms required to be submitted

1	Room name					Den					Dining				
2	Exposed wall					10.0 ft					9.5 ft				
3	Room height					9.0 ft					9.0 ft				
4	Room dimensions					10.0 x 15.0 ft					9.5 x 13.6 ft				
5	Room area					150.0 ft²					128.8 ft²				
	Ty	Construction number	U-value (Btuh/ft²·°F)	Or	HTM (Btuh/ft²)		Area (ft²) or perimeter (ft)		Load (Btuh)		Area (ft²) or perimeter (ft)		Load (Btuh)		
					Heat	Cool	Gross	N/P/S	Heat	Cool	Gross	N/P/S	Heat	Cool	
6	W	12F-0bw	0.065	n	4.27	0.80	90	80	342	64	86	76	322	60	
11	G	10D-c	0.350	n	22.99	7.73	0	0	0	0	0	0	0	0	
	G	4A5-2oc	0.350	n	22.99	11.05	10	0	230	110	10	0	230	110	
	W	12F-0bw	0.065	e	4.27	0.80	0	0	0	0	0	0	0	0	
	G	4A5-2oc	0.350	e	22.99	34.24	0	0	0	0	0	0	0	0	
	W	12F-0bw	0.065	s	4.27	0.80	0	0	0	0	0	0	0	0	
	G	4A5-2oc	0.350	s	22.99	18.46	0	0	0	0	0	0	0	0	
	D	11E0	0.260	s	17.08	7.32	0	0	0	0	0	0	0	0	
	W	12F-0bw	0.065	w	4.27	0.80	0	0	0	0	0	0	0	0	
	G	4A5-2oc	0.350	w	22.99	34.24	0	0	0	0	0	0	0	0	
	C	16C-38aw	0.026	-	1.71	1.08	150	150	256	162	128	128	219	139	
	F	19A-30bstp	0.034	-	1.87	0.42	150	150	281	62	128	128	240	53	

# Example of Manual J, D and S Forms required to be submitted

1	Room name					Kitchen					Living Room				
2	Exposed wall					26.5 ft					40.0 ft				
3	Room height					9.0 ft					9.0 ft				
4	Room dimensions					13.0 x 13.6 ft					22.5 x 17.5 ft				
5	Room area					176.3 ft²					393.8 ft²				
	Ty	Construction number	U-value (Btuh/ft²·°F)	Or	HTM (Btuh/ft²)		Area (ft²) or perimeter (ft)		Load (Btuh)		Area (ft²) or perimeter (ft)		Load (Btuh)		
					Heat	Cool	Gross	N/P/S	Heat	Cool	Gross	N/P/S	Heat	Cool	
6 . . . 11	W	12F-0bw	0.065	n	4.27	0.80	117	107	457	85	0	0	0	0	
	G	10D-c	0.350	n	22.99	7.73	0	0	0	0	0	0	0	0	
	G	4A5-2oc	0.350	n	22.99	11.05	10	0	230	110	0	0	0	0	
	W	12F-0bw	0.065	e	4.27	0.80	122	107	455	85	158	128	544	102	
	G	4A5-2oc	0.350	e	22.99	34.24	15	0	345	514	30	0	690	1027	
	W	12F-0bw	0.065	s	4.27	0.80	0	0	0	0	203	139	595	111	
	G	4A5-2oc	0.350	s	22.99	18.46	0	0	0	0	42	0	968	777	
	D	11E0	0.260	s	17.08	7.32	0	0	0	0	21	21	359	154	
	W	12F-0bw	0.065	w	4.27	0.80	0	0	0	0	0	0	0	0	
	G	4A5-2oc	0.350	w	22.99	34.24	0	0	0	0	0	0	0	0	
	C	16C-38aw	0.026	-	1.71	1.08	176	176	300	190	394	394	673	426	
F	19A-30bstp	0.034	-	1.87	0.42	176	176	329	73	394	394	738	164		

# Example of Manual J, D and S Forms required to be submitted

1	Room name					CL 2					Bedroom 2				
2	Exposed wall					4.0 ft					28.0 ft				
3	Room height					9.0 ft					9.0 ft				
4	Room dimensions					8.5 x 4.0 ft					16.0 x 12.0 ft				
5	Room area					34.0 ft²					192.0 ft²				
	Ty	Construction number	U-value (Btuh/ft²·°F)	Or	HTM (Btuh/ft²)		Area (ft²) or perimeter (ft)		Load (Btuh)		Area (ft²) or perimeter (ft)		Load (Btuh)		
					Heat	Cool	Gross	N/P/S	Heat	Cool	Gross	N/P/S	Heat	Cool	
6	W	12F-0bw	0.065	n	4.27	0.80	0	0	0	0	0	0	0	0	
11	G	10D-c	0.350	n	22.99	7.73	0	0	0	0	0	0	0	0	
	G	4A5-2oc	0.350	n	22.99	11.05	0	0	0	0	0	0	0	0	
	W	12F-0bw	0.065	e	4.27	0.80	0	0	0	0	0	0	0	0	
	G	4A5-2oc	0.350	e	22.99	34.24	0	0	0	0	0	0	0	0	
	W	12F-0bw	0.065	s	4.27	0.80	0	0	0	0	144	132	563	105	
	G	4A5-2oc	0.350	s	22.99	18.46	0	0	0	0	12	0	278	223	
	D	11E0	0.260	s	17.08	7.32	0	0	0	0	0	0	0	0	
	W	12F-0bw	0.065	w	4.27	0.80	36	36	154	29	108	88	377	70	
	G	4A5-2oc	0.350	w	22.99	34.24	0	0	0	0	20	0	452	673	
	C	16C-38aw	0.026	-	1.71	1.08	34	34	58	37	192	192	328	208	
	F	19A-30bstp	0.034	-	1.87	0.42	34	34	64	14	192	192	360	80	



# Example of Manual J,D and S Forms required to be submitted

1	Room name					Hall 0 ft					Bath 2 7.5 ft				
2	Exposed wall					9.0 ft					9.0 ft				
3	Room height					31.5 x 4.0 ft					7.5 x 12.0 ft				
4	Room dimensions					126.0 ft²					90.0 ft²				
5	Room area														
	Ty	Construction number	U-value (Btuh/ft²·°F)	Or	HTM (Btuh/ft²)		Area (ft²) or perimeter (ft)		Load (Btuh)		Area (ft²) or perimeter (ft)		Load (Btuh)		
					Heat	Cool	Gross	N/P/S	Heat	Cool	Gross	N/P/S	Heat	Cool	
6	W	12F-0bw	0.065	n	4.27	0.80	0	0	0	0	0	0	0	0	
11	G	10D-c	0.350	n	22.99	7.73	0	0	0	0	0	0	0	0	
	G	4A5-2oc	0.350	n	22.99	11.05	0	0	0	0	0	0	0	0	
	W	12F-0bw	0.065	e	4.27	0.80	0	0	0	0	0	0	0	0	
	G	4A5-2oc	0.350	e	22.99	34.24	0	0	0	0	0	0	0	0	
	W	12F-0bw	0.065	s	4.27	0.80	0	0	0	0	68	68	288	54	
	G	4A5-2oc	0.350	s	22.99	18.46	0	0	0	0	0	0	0	0	
	D	11E0	0.260	s	17.08	7.32	0	0	0	0	0	0	0	0	
	W	12F-0bw	0.065	w	4.27	0.80	0	0	0	0	0	0	0	0	
	G	4A5-2oc	0.350	w	22.99	34.24	0	0	0	0	0	0	0	0	
	C	16C-38aw	0.026	-	1.71	1.08	126	126	215	136	90	90	154	97	
	F	19A-30bstp	0.034	-	1.87	0.42	126	126	236	52	90	90	169	37	

# Example of Manual J, D and S

## Forms required to be submitted

1	Room name					Bedroom 3								
2	Exposed wall					16.5 ft								
3	Room height					9.0 ft					heat/cool			
4	Room dimensions					16.5 x 12.0 ft								
5	Room area					198.0 ft²								
	Ty	Construction number	U-value (Btuh/ft²·°F)	Or	HTM (Btuh/ft²)		Area (ft²) or perimeter (ft)		Load (Btuh)		Area or perimeter		Load	
					Heat	Cool	Gross	N/P/S	Heat	Cool	Gross	N/P/S	Heat	Cool
6	W	12F-0bw	0.065	n	4.27	0.80	0	0	0	0				
11	G	10D-c	0.350	n	22.99	7.73	0	0	0	0				
	G	4A5-2oc	0.350	n	22.99	11.05	0	0	0	0				
	W	12F-0bw	0.065	e	4.27	0.80	0	0	0	0				
	G	4A5-2oc	0.350	e	22.99	34.24	0	0	0	0				
	W	12F-0bw	0.065	s	4.27	0.80	149	129	549	102				
	G	4A5-2oc	0.350	s	22.99	18.46	20	0	460	369				
	D	11E0	0.260	s	17.08	7.32	0	0	0	0				
	W	12F-0bw	0.065	w	4.27	0.80	0	0	0	0				
	G	4A5-2oc	0.350	w	22.99	34.24	0	0	0	0				
	C	16C-38aw	0.026	-	1.71	1.08	198	198	338	214				
	F	19A-30bstp	0.034	-	1.87	0.42	198	198	371	82				
</														

**Project Summary**  
**Entire House**

Job: SEG 0314-077W  
Date: Mar 17, 2014

# Example of Manual J,D and S Forms required to be submitted

## Project Information

For: Right-Sized Residence  
ACCA Manual J Street, Oak Park, IL 60301

Notes: Joe Contractor  
Superior HVAC

## Design Information

Weather: Chicago Midway AP, IL, US

### Winter Design Conditions

Outside db	4 °F
Inside db	70 °F
Design TD	66 °F

### Summer Design Conditions

Outside db	90 °F
Inside db	75 °F
Design TD	15 °F
Daily range	L
Relative humidity	50 %
Moisture difference	34 gr/lb

### Heating Summary

Structure	28787 Btuh
Ducts	11276 Btuh
Central vent (33 cfm)	2335 Btuh
Humidification	0 Btuh
Piping	0 Btuh
Equipment load	42397 Btuh

### Infiltration

Method	Simplified
Construction quality	Average
Fireplaces	2 (Average)

	Heating	Cooling
Area (ft <sup>2</sup> )	1939	1939
Volume (ft <sup>3</sup> )	17450	17450
Air changes/hour	0.47	0.20
Equiv. AVF (cfm)	138	58

### Heating Equipment Summary

Make	Goodman Mfg.
Trade	GOODMAN
Model	GCH950453BX**
AHRI ref	3653909

Efficiency	95 AFUE
Heating input	46000 Btuh
Heating output	44000 Btuh
Temperature rise	51 °F
Actual air flow	800 cfm
Air flow factor	0.020 cfm/Btuh
Static pressure	0.60 in H2O
Space thermostat	

### Sensible Cooling Equipment Load Sizing

Structure	12298 Btuh
Ducts	3638 Btuh
Central vent (33 cfm)	519 Btuh
Blower	0 Btuh

Use manufacturer's data	y
Rate/swing multiplier	1.00
Equipment sensible load	16454 Btuh

### Latent Cooling Equipment Load Sizing

Structure	2120 Btuh
Ducts	1740 Btuh
Central vent (33 cfm)	750 Btuh
Equipment latent load	4609 Btuh

Equipment total load	21064 Btuh
Req. total capacity at 0.78 SHR	1.8 ton

### Cooling Equipment Summary

Make	Goodman Mfg.
Trade	GOODMAN
Cond	SSX160241B*
Coil	CA*F3636*6D*
AHRI ref	4652177

Efficiency	13.2 EER, 16 SEER
Sensible cooling	18720 Btuh
Latent cooling	5280 Btuh
Total cooling	24000 Btuh
Actual air flow	800 cfm
Air flow factor	0.050 cfm/Btuh
Static pressure	0.60 in H2O
Load sensible heat ratio	0.78

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.





# Example of Manual J, D and S for HVAC System Design (Loads, Equipment, Ducts) Forms required to be submitted

Form  
RPER 1  
15 Mar 09

## Header Information

Contractor:

Mechanical license:

Building plan #:

Home address (Street or Lot#, Block, Subdivision): ACCA Manual J Street, Entire House

### REQUIRED ATTACHMENTS

Manual J1 Form (and supporting worksheets):  
or MJ1AE Form\* (and supporting worksheets):  
OEM performance data (heating, cooling, blower):  
Manual D Friction Rate Worksheet:  
Duct distribution sketch:

### ATTACHED

Yes	<input type="checkbox"/>	No	<input type="checkbox"/>
Yes	<input type="checkbox"/>	No	<input type="checkbox"/>
Yes	<input type="checkbox"/>	No	<input type="checkbox"/>
Yes	<input type="checkbox"/>	No	<input type="checkbox"/>
Yes	<input type="checkbox"/>	No	<input type="checkbox"/>

## HVAC LOAD CALCULATION (IRC M1401.3)

### Design Conditions

#### Winter Design Conditions

Outdoor temperature: 4 °F  
Indoor temperature: 70 °F  
Total heat loss: 42397 Btuh

#### Summer Design Conditions

Outdoor temperature: 90 °F  
Indoor temperature: 75 °F  
Grains difference: 34 gr/lb @ 50% RH  
Sensible heat gain: 16454 Btuh  
Latent heat gain: 4609 Btuh  
Total heat gain: 21064 Btuh

### Building Construction Information


#### Building

Orientation: Front Door faces South  
North, East, West, South, Northeast, Northwest, Southeast, Southwest

Number of bedrooms: 3  
Conditioned floor area: 1939 ft<sup>2</sup>  
Number of occupants: 4

#### Windows

Eave overhang depth: 0 ft  
Internal shade: none  
Blinds, drapes, etc.  
Number of skylights: 0



## HVAC EQUIPMENT SELECTION (IRC M1401.3)

### Heating Equipment Data

Equipment type: Gas furnace  
Furnace, Heat pump, Boiler, etc.  
Model: Goodman Mfg.  
GCH950453BX\*\*+  
Heating output capacity: 44000 Btuh  
Heat pumps - capacity at winter design outdoor conditions  
Aux. heating output capacity: 0 Btuh

### Cooling Equipment Data

Equipment type: Split AC  
Air Conditioner, Heat pump, etc.  
Model: Goodman Mfg.  
SSX160241B\*+CA\*F3636\*6D\*  
Total cooling capacity: 23021 Btuh  
Sensible cooling capacity: 18121 Btuh  
Latent cooling capacity: 4900 Btuh

### Blower Data

Heating cfm: 800  
Cooling cfm: 800  
Static pressure: 0.60 in H<sub>2</sub>O  
Fan's rated external static pressure for design airflow

## HVAC DUCT DISTRIBUTION SYSTEM DESIGN (IRC M1601.1)

Design airflow: 800 cfm	Longest supply duct: 232 ft	Duct Materials Used
Equipment design ESP: 0.60 in H <sub>2</sub> O	Longest return duct: 197 ft	Trunk duct: Sheet metal
Total device pressure losses: -0.3 in H <sub>2</sub> O	Total effective length (TEL): 429 ft	Branch duct: Round flex vinyl, Sheet metal
Available static pressure (ASP): 0.33 in H <sub>2</sub> O	Friction rate: 0.077 in/100ft	

Friction Rate = ASP ÷ (TEL x 100)

I declare the load calculation, equipment, equipment selection and duct design were rigorously performed based on the building plan listed above. I understand the claims made on these forms will be subject to review and verification.

Contractor's printed name: \_\_\_\_\_

Contractor's signature: \_\_\_\_\_

Date: \_\_\_\_\_

Reserved for County, Town Municipality or Authority having jurisdiction use.

\*Home qualifies for MJ1AE Form based on Abridged Edition Checklist

**Duct System Summary**  
**Entire House**

Job: SEG 0314-077W  
 Date: Mar 17, 2014

# Example of Manual J, D and S Forms required to be submitted

## Project Information

For: Right-Sized Residence  
 ACCA Manual J Street, Oak Park, IL 60301

	Heating	Cooling
External static pressure	0.60 in H <sub>2</sub> O	0.60 in H <sub>2</sub> O
Pressure losses	0.27 in H <sub>2</sub> O	0.27 in H <sub>2</sub> O
Available static pressure	0.33 in H <sub>2</sub> O	0.33 in H <sub>2</sub> O
Supply / return available pressure	0.178 / 0.152 in H <sub>2</sub> O	0.178 / 0.152 in H <sub>2</sub> O
Lowest friction rate	0.077 in/100ft	0.077 in/100ft
Actual air flow	800 cfm	800 cfm
Total effective length (TEL)	429 ft	

## Supply Branch Detail Table

Name	Design (Btuh)	Htg (cfm)	Clg (cfm)	Design FR	Diam (in)	H x W (in)	Duct Matl	Actual Ln (ft)	Ftg.Eqv Ln (ft)	Trunk
Bath 2	h 1481	30	16	0.084	4.0	0x0	VIFx	21.3	190.0	st5
Bedroom 2	h 5733	114	113	0.115	7.0	0x0	VIFx	29.5	125.0	st4
Bedroom 3	h 3780	75	62	0.081	5.0	0x0	VIFx	29.5	190.0	st5
Den	h 2507	50	32	0.082	4.0	0x0	VIFx	33.5	185.0	st6
Dining	h 2095	42	25	0.080	6.0	0x0	VIFx	44.0	180.0	st7
Kitchen	c 1633	49	82	0.078	6.0	0x0	VIFx	54.5	175.0	st10
Kitchen-A	c 1633	49	82	0.077	6.0	0x0	VIFx	56.5	175.0	st10
Living Room	c 2264	93	114	0.087	7.0	0x0	VIFx	54.3	150.0	st11
Living Room-A	c 2264	93	114	0.088	7.0	0x0	VIFx	53.2	150.0	st11
Master Bath	h 2734	55	30	0.084	5.0	0x0	VIFx	22.0	190.0	st5
Master Bedroom	h 3787	76	66	0.107	5.0	0x0	VIFx	31.7	135.0	st2
Master Bedroom-A	h 3787	76	66	0.107	5.0	0x0	VIFx	32.3	135.0	st2

## Supply Trunk Detail Table

Name	Trunk Type	Htg (cfm)	Clg (cfm)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Duct Material	Trunk
st10	Peak AVF	97	164	0.077	470	8.0	0 x 0	ShtMetl	st7
st7	Peak AVF	325	417	0.077	764	10.0	0 x 0	ShtMetl	st6
st6	Peak AVF	375	449	0.077	572	12.0	0 x 0	ShtMetl	st5
st5	Peak AVF	534	556	0.077	708	12.0	0 x 0	ShtMetl	st1
st2	Peak AVF	151	131	0.107	566	7.0	0 x 0	ShtMetl	st4
st4	Peak AVF	266	244	0.107	761	8.0	0 x 0	ShtMetl	st1
st11	Peak AVF	186	227	0.087	850	7.0	0 x 0	ShtMetl	st7
st1	Peak AVF	800	800	0.077	453	18.0	0 x 0	ShtMetl	

# Return Branch Detail Table

Example of Manual J,D and S  
Forms required to be submitted

Name	Grill Size (in)	Htg (cfm)	Clg (cfm)	TEL (ft)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Stud/Joist Opening (in)	Duct Material	Trunk
rb2	20x11	375	449	197.0	0.077	572	12.0	0x 0		ShMt	rt3
rb5	10x10	206	161	130.5	0.116	590	8.0	0x 0		ShMt	rt1
rb3	10x10	144	128	126.5	0.120	539	7.0	0x 0		ShMt	rt4
rb4	6x10	75	62	185.5	0.082	384	6.0	0x 0		ShMt	rt3

# Return Trunk Detail Table

Name	Trunk Type	Htg (cfm)	Clg (cfm)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Duct Material	Trunk
rt3	Peak AVF	450	511	0.077	650	12.0	0 x 0	ShtMetl	rt2
rt1	Peak AVF	800	800	0.077	573	16.0	0 x 0	ShtMetl	
rt2	Peak AVF	594	639	0.077	598	14.0	0 x 0	ShtMetl	rt1
rt4	Peak AVF	144	128	0.120	413	8.0	0 x 0	ShtMetl	rt2



# Example of Manual J, D and S Forms required to be submitted

## Project Information

For: Right-Sized Residence  
ACCA Manual J Street, Oak Park, IL 60301

## Cooling Equipment

### Design Conditions

Outdoor design DB: 89.6°F	Sensible gain: 16454 Btuh	Entering coil DB: 77.0°F
Outdoor design WB: 73.3°F	Latent gain: 4609 Btuh	Entering coil WB: 64.1°F
Indoor design DB: 75.0°F	Total gain: 21064 Btuh	
Indoor RH: 50%	Estimated airflow: 800 cfm	

### Manufacturer's Performance Data at Actual Design Conditions

Equipment type: Split AC	
Manufacturer: Goodman Mfg.	Model: SSX160241B*+CA*F3636*6D*
Actual airflow: 800 cfm	
Sensible capacity: 18121 Btuh	110% of load
Latent capacity: 4900 Btuh	106% of load
Total capacity: 23021 Btuh	109% of load SHR: 79%

## Heating Equipment

### Design Conditions


Outdoor design DB: 4.3°F	Heat loss: 42397 Btuh	Entering coil DB: 60.8°F
Indoor design DB: 70.0°F		

### Manufacturer's Performance Data at Actual Design Conditions

Equipment type: Gas furnace	
Manufacturer: Goodman Mfg.	Model: GCH950453BX**
Actual airflow: 800 cfm	
Output capacity: 44000 Btuh	104% of load
	Temp. rise: 50 °F

The above equipment was selected in accordance with ACCA Manual S.

# Example of Manual J,D and S Forms required to be submitted



Job #: SEG 0314-077W

Right-Sized Residence  
ACCA Manual J Street  
Oak Park, IL 60301

Phone:

Scale: 1 : 81

Page 1

2014-Mar-18 18:57:36

# Reviewing HVAC Designs for Compliance with ACCA Manual S

by Wes Davis

An approved code change to the 2009 *International Residential Code* (IRC) clarifies an existing requirement for sizing HVAC equipment: "Heating and cooling equipment shall be sized in accordance with ACCA Manual S based on building loads calculated in accordance with ACCA Manual J or other approved heating and cooling calculation methodologies" (emphasis added).

Air Conditioning Contractors of America (ACCA) Manual S, *Residential Heating and Cooling Equipment Selection*, provides clear instructions for interpreting and applying original equipment manufacturer (OEM) expanded performance data to select equipment that meets application requirements (heating, sensible cooling or latent cooling) for the applied design conditions used to calculate loads with ACCA Manual J, *Residential Load Calculation*. It also provides the methodology for identifying the blower airflow design value, in cubic feet per minute (cfm), which is subsequently used per IRC Section 1601.1 with ACCA Manual D, *Residential Duct Systems*, to calculate duct sizing.

In addition, Manual S sets equipment sizing limits, as summarized in Table 1. These sizing limits ensure






Table 1. Manual S equipment selection sizing limitations.

Equipment	Sizing Limitations	Reference (section)
Furnaces	100–140% of total heating load	2-2
boilers	100–140% of total heating load	2-2
air conditioners	115% of total cooling load*	3-4
heat pumps	115% <sup>1</sup> or 125% <sup>2</sup> of total cooling load*	4-4
supplemental heat (heat pumps)		
electric	based on equipment balance point	4-8
dual fuel	100–140% of total heating load	6-8
emergency heat (heat pumps)	based on local codes	4-9

1. Heat pumps in a cooling dominant climate are allowed to be 115% of the cooling level.

2. Heat pumps in a heating dominant climate are allowed to be 125% of the cooling level.

\*The size of the cooling equipment must be based on the same temperature and humidity conditions that were used to calculate the Manual J loads.

that equipment capacities meet the minimum needs of occupants while preventing the problems associated with oversizing.<sup>1</sup>

## How to Apply Manual S

### Heating, Part One

Manual J heating load calculations produce values, in British thermal units per hour (BTU/h), for selecting HVAC equipment.

Take for example a home that requires a minimum of 56,000 Btu/h of heat to maintain an indoor temperature of 70°F when the outdoor temperature drops in the winter. Based on the sizing limitations (100%–140% of heating load), the furnace must have a capacity between 56,000

Btu/h and 78,400 Btu/h (140% x 56,000). Per the manufacturer's product data given in Figure 1, XYZ model FR 80-036—with an output capacity of 64,000 Btu/h—meets the requirement. Model FR 80-024 does not meet the minimum design temperature, while FR 125-036 has too much output capacity.

### Cooling

The cooling loads given in Manual J for the example home are: total cooling = 30,000 Btu/h, sensible cooling = 22,000 Btu/h and latent cooling = 8,000 Btu/h. Based on the Manual S sizing limitations (100%–115% of the cooling load), the air conditioner must have a capacity between 30,000 Btu/h and 34,500 Btu/h (115% x 30,000).

Table 2. Manual D input for design air flow.

Mode of Operation	Requirement	Reference (section)
heating	temperature rise requirement	2-6
cooling	air flow associated with the selected equipment's capacity	3-11

Table 3. Example cooling design conditions.

Indoor Conditions			Outdoor Conditions
design temperature	relative design humidity	indoor wet-bulb temperature (at 75°F and 50% Rh)	design temperature
75°F	50% Rh	63°F wet-bulb	95°F

When selecting cooling equipment, it is necessary to know the design conditions used to calculate the cooling load. Unlike heating equipment, cooling equipment OEM data offers a range of performance at different outdoor and indoor conditions. The design conditions for the example home are given in Table 3.

Figures 2 and 3 provide OEM expanded performance data for two air conditioners: a 2.5-ton capacity model and a 3.0-ton capacity model. Manufacturers may present this data in a different format, but all should include airflow, entering air wet-bulb temperature,<sup>2</sup> outdoor temperature, and cooling capacities (usually, total and sensible capacities). Note that a slightly different approach is employed when using Manual S to verify cooling equipment selection than to select the equipment. Verification begins by considering the outdoor air temperature and indoor wet-bulb temperature.

The 2.5-ton air conditioner seems like a natural choice for a home with a 30,000 Btu/h cooling load because a 2.5-ton unit has a nominal capacity of 30,000 Btu/h. However, the OEM data for XYZ model AC-30 reveals that the unit does not meet the Manual S total cooling capacity requirement at the design 95°F outdoor temperature and 63°F entering wet-bulb temperature. In contrast, according to the OEM data, XYZ model AC-36 has enough total cooling capacity (31,510 Btu/h) without exceeding the 115-percent limit (34,500 Btu/h). The system's sensible cooling capacity (23,000 Btu/h) also meets the sensible cooling load (22,000 Btu/h) and the latent capacity (total capacity – sensible capacity = latent capacity 8,510 Btu/h) meets the latent load (8,000 Btu/h).


Another critical design element is the volume of air that must flow over the indoor air conditioner coil to achieve the required cooling capacities.<sup>3</sup> The furnace manufacturer will provide blower performance data indicating the air flow that the unit can deliver at different levels of resistance. Referring to the fan performance data given in Figure 4 for XYZ model FR 80-036 (1,035 cfm at 0.60 inches water column [iwc], interpolated to 1,050 cfm at 0.58 iwc), the furnace can deliver the airflow required per ACCA Manual D.

### Heating, Part Two

Given the duct design value of 1,050 cfm, the final hurdle is to determine if the unit selection meets the furnace requirements for temperature rise. Referring back to Figure 1, the XYZ model FR 80-036 furnace has an OEM

## Sensible and Latent Loads

There are two aspects to the consideration of cooling load: sensible and latent loads. The sensible load is the heat that is measured by a thermometer or a thermostat. This is the “dry” heat one consciously feels. The latent load is the heat associ-



ated with airborne moisture as measured by a hygrometer or humidistat.

When you enter a home whose thermostat shows a cool temperature but which has high latent heat—or relative humidity—the initial feeling is comfort. But as your body adjusts to the temperature you begin to feel sticky, clammy and uncomfortable. You may even feel warm again. This is why two homes with the same thermostat setting can feel very different.

XYZ Furnace Company						
General Data				Input Capacity		Output Capacity
Efficiency						
Unit Size	FR60-024	FR 60-036	FR 80-024	FR 80-036	FR 125-036	FR 125-048
Output Capacity						
Upflow	48,000	48,000	64,000	64,000	100,000	100,000
Horizontal	48,000	48,000	64,000	64,000	100,000	100,000
Input Btu/h	60,000	60,000	80,000	80,000	125,000	125,000
Temp Rise Range	30 – 60	15 – 45	45 – 75	35 – 65	40 – 70	30 – 60

Figure 1. Furnace product data for XYZ 3.0-ton air conditioners.



Model AC-30 with Coil AC-030 (2.5 ton)											
Evaporator Air		Condenser Entering Air Temp – DB (F)									
CFM	EWB (F)	75		85		95		105		115	
		Capacity		Capacity		Capacity		Capacity		Capacity	
		Total	Sensible	Total	Sensible	Total	Sensible	Total	Sensible	Total	Sensible
875	72	34,610	18,190	33,100	17,620	29,830	16,390	28,040	15,730	26,500	15,170
	67	31,400	22,240	30,000	21,650	28,520	21,040	26,960	20,390	25,300	19,720
	63	28,620	26,290	27,350	25,680	26,020	25,040	24,640	24,340	23,340	23,340
	57	27,840	27,840	26,820	26,820	25,740	25,740	24,580	24,580	23,340	23,340
1000	72	35,250	19,090	33,680	18,500	32,030	17,890	30,280	17,260	28,430	16,590
	67	31,990	23,660	30,530	23,060	29,000	22,440	27,380	21,790	25,670	21,110
	63	29,300	28,220	28,020	27,560	26,770	26,770	25,540	25,540	24,220	24,220
	57	29,020	29,020	27,930	27,930	26,780	26,780	25,540	25,540	24,230	24,230
1125	72	35,720	19,920	34,110	19,330	32,410	18,710	30,610	18,070	28,700	17,390
	67	32,430	25,010	30,930	24,410	29,360	23,780	27,700	23,120	25,960	22,420
	63	29,970	29,970	28,850	28,850	27,630	27,630	26,340	26,340	24,950	24,950
	57	30,000	30,000	28,850	28,850	27,640	27,640	26,340	26,340	24,950	24,950

Figure 2. OEM performance data for XYZ AC-30 2.5-ton air conditioner.

Model AC-36 with Coil AC-036 (3.0 ton)											
Evaporator Air		Condenser Entering Air Temp – DB (F)									
CFM	EWB (F)	75		85		95		105		115	
		Capacity		Capacity		Capacity		Capacity		Capacity	
		Total	Sensible	Total	Sensible	Total	Sensible	Total	Sensible	Total	Sensible
1050	72	41,680	21,820	39,850	21,110	37,920	20,380	35,900	19,620	33,700	18,810
	67	37,930	24,680	36,260	23,950	34,460	21,200	32,570	24,420	30,540	23,590
	63	34,660	29,520	33,120	28,780	31,510	23,000	29,840	29,160	28,150	28,150
	57	33,650	31,650	32,400	30,400	31,090	27,090	29,680	29,680	28,160	28,160
1200	72	42,390	20,820	40,490	20,100	38,490	21,360	36,390	29,590	34,130	19,770
	67	38,650	26,290	36,870	25,560	35,000	26,790	33,949	26,010	30,950	25,170
	63	35,450	31,740	33,890	30,950	32,300	32,080	30,790	30,790	29,180	29,180
	57	35,020	33,020	33,690	31,690	32,290	32,290	30,800	30,800	29,190	29,190
1350	72	42,910	21,750	40,960	21,030	38,890	22,280	36,750	21,510	34,420	20,680
	67	39,150	27,820	37,320	27,080	35,410	28,320	33,410	27,530	31,270	26,680
	63	36,200	33,760	34,750	32,750	33,270	33,270	31,700	31,700	30,010	30,010
	57	36,160	34,160	34,760	32,760	33,270	33,270	31,710	31,710	30,010	30,010

Figure 3. OEM performance data for XYZ AC-36 3.0-ton air conditioner.

### AHRI Versus OEM Expanded Performance Data

Manufacturers of heating and cooling equipment are responsible for testing and certifying the performance of their products. The Air Conditioning, Heating and Refrigeration Institute (AHRI) produces standards for rating such equipment, but data published in AHRI product directories should not be used because the test conditions simulate a very small geographic area in the U.S. As such, AHRI directories should only be used to compare equipment efficiency ratings—OEM expanded performance data should be used to select properly sized equipment.

design temperature rise range of 35°F–65°F

Air temperature rise through the furnace depends on the rate of flow through the heat exchanger. If the air flow is outside of the temperature rise range, the equipment may cycle off at safety limits, suffer damage or possibly even create an unsafe condition. Incorrect air flow can cause too much temperature rise (slow-moving air may allow the heat exchanger to become too hot, which can result in warping or cracking of the metal heat exchanger) or too little temperature rise (fast-moving air may cause condensation in the metal heat exchanger, which can result in the production of an acid that can harm or penetrate the heat exchanger).

(continued on page 26.)



XYZ Company FR 80-036								
Air Delivery – CFM ( with filter)								
Unit Size	Speed	External Static Pressure (inches water column)						
		0.1	0.2	0.3	0.4	0.5	0.6	0.7
FR80 - 024	High	1075	1040	995	945	895	840	760
	Med – Hi	950	925	895	845	795	740	660
	Med – Lo	850	825	780	740	685	635	560
	Low	740	700	650	620	565	515	455
FR80 - 036	High	1470	1415	1400	1285	1215	1120	995
	Med – Hi	1315	1280	1235	1298	1115	1035	930
	Med – Lo	1125	1110	1085	1045	995	915	830
	Low	930	9256	910	850	830	770	705
FR80 - 048	High	1700	1685	1640	1580	1545	1450	1380
	Med – Hi	1500	1465	1435	1385	1255	1300	1250
	Med – Lo	1325	1295	1265	1230	1190	1150	1105
	Low	1205	1170	1145	1110	1080	1035	990

Note: Airflow based on a bottom only return air, 120v, with factory supplied 1-in filter (0.05 IWC).

Figure 4. Fan performance data.

An air flow rate is acceptable if it yields a temperature rise within the range prescribed by the equipment manufacturer. In our example, 1,050 cfm equates to an acceptable (35°F–65°F) furnace temperature rise of approximately 55°F:

$$\Delta T = \text{Btu/h}^4 \div (\text{CFM} \times 1.1 \times \text{ACF})$$

$$55.4^\circ\text{F} = 64,000 \div (1,050 \times 1.1 \times 1.0)$$

where:

$\Delta T$  = temperature difference in the air between the inlet and outlet of the furnace or cooling coil

$\text{Btu/h}$  = thermal output capacity of the furnace or cooling system

$\text{CFM}$  = volume of air, in cubic feet per minute, moved through the furnace by the blower assembly

1.1 = a physical air constant (derived from the laws of physics)

$\text{ACF}$  = altitude correction factor; 1.0 at sea level

## Notes

1. Oversizing can lead to health issues associated with excessive humidity; higher costs for equipment and installation labor and materials; greater energy consumption; and more wear and tear on equipment.
2. This considers both the temperature and moisture content of the air.
3. When the blower moves 1,050 cfm over the XYZ model AC-36 indoor air conditioner coil, it delivers the required cooling capacity. If the airflow value changes, the equipment capacity and performance also change.
4. In this case, the actual furnace output capacity of 64,000 Btu/h is used, not the 56,000 Btu/h design capacity from the load calculation.

**WES DAVIS** is Manager of Technical Services for the Air Conditioning Contractors of America (ACCA), in which capacity he develops HVAC-oriented technical documents, delivers educational presentations and provides technical support to ACCA members.

He is the author of *Bob's House*, a step-by-step case study in the proper design of a residential HVAC system; serves on several industry technical committees; and coordinated the development of ACCA's Quality Maintenance Standard and Quality Installation Verification Protocols.

## Conclusion

This article serves to demonstrate the value of the adopted code revision in ensuring that appropriate load calculations are used as the basis for HVAC equipment selection: one more way that First Preventers can protect the health and safety of building occupants across the country. ♦