

Energy Efficiency		Walls insulated per plans (min R-13) [IRC 1101]
Energy Efficiency		ICC evaluation required for spray foam [LSUCCC]
Energy Efficiency		Window U-Factor (0.65 or less) / SHGC (0.35 or less) [IRC N1100]
Energy Efficiency		Exterior thermal envelope insulation (R-13) for framed walls is installed in substantial contact and continuous alignment with building envelope air barrier. Breaks or joints in the air barrier are filled or repaired. Air-permeable insulation is not used as a sealing material [IRC Table 1102.4.2].
Energy Efficiency		Corners and headers are insulated. Junction of foundation and sill plate is sealed [IRC Table 1102.4.2].
Energy Efficiency		Space between window/door jambs and framing is sealed [IRC Table 1102.4.2].
Energy Efficiency		Rim Joists are insulated and include an air barrier [IRC Table 1102.4.2].
Energy Efficiency		Duct shafts, utility penetrations, and flue shafts opening to exterior or unconditioned space shall be sealed [IRC Table 1102.4.2].
Energy Efficiency		Batts in narrow cavities shall be cut to fit, or narrow cavities are filled by sprayed or blown insulation [IRC Table 1102.4.2].
Energy Efficiency		Air sealing is provided between the garage and conditioned spaces [IRC Table 1102.4.2].
Energy Efficiency		Insulation is placed between outside and pipes. Batt insulation is cut to fit around wiring and plumbing, or sprayed/blown insulation extends behind piping and wiring [IRC Table 1102.4.2].
Energy Efficiency		Showers and tubs on exterior walls have insulation and an air barrier separating them from the exterior wall [IRC Table 1102.4.2].
Energy Efficiency		Air barrier extends behind boxes or air sealed type boxes are installed [IRC Table 1102.4.2].
Energy Efficiency		Air barrier is installed in common wall between dwelling units [IRC Table 1102.4.2].
Energy Efficiency		Fireplace walls include an air barrier [IRC Table 1102.4.2].
Energy Efficiency		IC rated and Labeled recessed lighting [IRC N1102.4.5]